Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# *2309*

Customer

Facility Name:	Koa Campground
Address:	7 Koa Road, Washington, PA 15301
Matrix:	Recreational Water
Source Type:	Pool

Sample Collection

Date:	7/1/25
Time:	9:21 AM
Method:	Grab

Sample Final Analysis

Date:	7/4/25
Time:	9:30 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	9:21 AM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/1/25	9:21 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	9:21 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 2309

Customer

Facility Name:	Koa Campground
Address:	7 Koa Road, Washington, PA 15301
Matrix:	Recreational Water
Source Type:	Pool

Sample Collection

Date:	7/1/25
Time:	9:21 AM
Method:	Grab

Sample Final Analysis

Date:	7/4/25
Time:	9:30 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	9:21 AM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/1/25	9:21 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	9:21 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor