



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 300

Customer

Facility Name: Trinity Middle School
Address: 50 Scenic Dr.
Washington, PA 15301

Sample Collection

Date: 11/10/25
Time: 8:36 AM
Method: Grab

Matrix: Recreational Water

Source Type: Pool

Sample Final Analysis

Date: 11/13/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/11/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/11/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/10/25	5:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	11/10/25	8:36 AM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/10/25	8:36 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/10/25	8:36 AM	GR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)