

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-13

Lab# 433

Customer

Facility Name:

Atria Senior Living

Address:

8870 Duncan Ave.

Pittsburgh, PA 15237

Matrix:

Recreational Water

Source Type:

Pool

Sample Collection

Date:

6/16/25 12:16 PM

Time: Method:

Grab

Sample Final Analysis

Date:

6/19/25

Time:

10:00 AM

Analyst:

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	12:16 PM	MM	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25	12:16 PM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	12:16 PM	MM	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-13

Lab# 433

Customer

Facility Name:

Atria Senior Living

Address:

8870 Duncan Ave.

Pittsburgh, PA 15237

Matrix:

Recreational Water

Source Type:

Pool

Sample Collection

Date:

6/16/25 12:16 PM

Time: Method:

Grab

Sample Final Analysis

Date:

6/19/25

Time:

10:00 AM

Analyst:

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	12:16 PM	MM	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25	12:16 PM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	12:16 PM	MM	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor