



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041

E - 11

Lab# 163

Customer

Facility Name: Holiday Inn Express

Address: 3695 State Rd, RT 31
Donegal, PA 15628

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/28/25

Time: 9:57 AM

Method: Grab

Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	10:00 AM	EB
Total coliforms:	0/100mls	2/100mls	7/29/25	10:00 AM	EB
Standard plate count:	0/ml	200/ml	7/28/25	4:45 PM	AH

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/29/25	11:30 AM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/28/25	9:57 AM	JC
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/25	9:57 AM	JC
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	9:57 AM	JC

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041

E - 11

Lab# 163

Customer

Facility Name: Holiday Inn Express

Address: 3695 State Rd, RT 31
Donegal, PA 15628

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/28/25

Time: 9:57 AM

Method: Grab

Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	10:00 AM	EB
Total coliforms:	0/100mls	2/100mls	7/29/25	10:00 AM	EB
Standard plate count:	0/ml	200/ml	7/28/25	4:45 PM	AH

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/29/25	11:30 AM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/28/25	9:57 AM	JC
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/25	9:57 AM	JC
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	9:57 AM	JC

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor