



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2652

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Kane @ Grey's Landing*

Address: *2971 Kane Road*
Aliquippa, PA 15001

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/28/25*
Time: *10:15 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/31/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	11:30 AM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	7/28/25	7:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	7/28/25	10:15 AM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/28/25	10:15 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	10:15 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2652

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Kane @ Grey's Landing*

Address: *2971 Kane Road*
Aliquippa, PA 15001

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/28/25*
Time: *10:15 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/31/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	11:30 AM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	7/28/25	7:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	7/28/25	10:15 AM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/28/25	10:15 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	10:15 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor