



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 502

Customer

Facility Name: Hampton by Hilton

Address: 202 Fairview Dr.
Monaca, PA 15061

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/2/25

Time: 2:54 PM

Method: Grab

Sample Final Analysis

Date: 12/5/25

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/25	10:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/25	10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/25	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/2/25	2:54 PM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/2/25	2:54 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/25	2:54 PM	GR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)