Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2494

Customer

				Sample Collection	
Facility Name:	South Hills Country Club			*Date:*	8/6/25
				Time:	12:03 PM
Address:	4305 Brownsville Road			*Method:*	Grab
	Pittsburgh, PA 15236				
				Sample Final Analysis	
Matrix:	Recreational Water			*Date:*	8/8/25
				Time:	2:00 PM
Source Type:	Deep End			*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25	3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	8/6/25	12:03 PM	ZS	DPD
Chlorine:	6.0 mg/l	1.0 - 5.0 mg/l	8/6/25	12:03 PM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25	12:03 PM	ZS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2494

Customer

Facility Name:	*South Hills Country Club*
Address:	*4305 Brownsville Road*
	Pittsburgh, PA 15236
Matrix:	*Recreational Water*
Source Type:	*Deep End*

Sample Collection

Date:	*8/6/25*
Time:	12:03 PM
Method:	*Grab*

Sample Final Analysis

Date:	*8/8/25*
Time:	*2:00 PM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25	3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	8/6/25	12:03 PM	ZS	DPD
Chlorine:	6.0 mg/l	1.0 - 5.0 mg/l	8/6/25	12:03 PM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25	12:03 PM	ZS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor