



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

S-15

Lab# 2142

**Customer**

Facility Name: Cranmoor Condominium

Address: 163 Roscommon Place  
Canonsburg, PA 15317

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 8/5/25

Time: 11:17 AM

Method: Grab

**Sample Final Analysis**

Date: 8/8/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	AH
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	AH
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	11:17 AM	AF
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:17 AM	AF
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:17 AM	AF

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

S-15

Lab# 2142

**Customer**

Facility Name: Cranmoor Condominium

Address: 163 Roscommon Place  
Canonsburg, PA 15317

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 8/5/25

Time: 11:17 AM

Method: Grab

**Sample Final Analysis**

Date: 8/8/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	AH
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	AH
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	11:17 AM	AF
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:17 AM	AF
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:17 AM	AF

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor