



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2577

Customer

Facility Name: White Oak Boro
Address: 169 Victoria Dr.
White Oak, PA 15131

Sample Collection

Date: 6/25/25
Time: 10:33 AM
Method: Grab

Matrix: Recreational Water
Source Type: Baby Pool

Sample Final Analysis

Date: 6/27/25
Time: 4:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	6:40 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	6:40 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	6/25/25	6:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/25/25	10:33 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/25/25	10:33 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	10:33 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2577

Customer

Facility Name: *White Oak Boro*

Address: *169 Victoria Dr.*
White Oak, PA 15131

Sample Collection

Date: *6/25/25*
Time: *10:33 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Baby Pool*

Sample Final Analysis

Date: *6/27/25*
Time: *4:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	6:40 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	6:40 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	6/25/25	6:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/25/25	10:33 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/25/25	10:33 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	10:33 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor