



**Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041
APM 1

Lab# 2062

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Brook Park Swim Club

Sample Collection

Date: 6/23/25

Address: 8190 Rochester Rd
Pittsburgh, PA 15237

Time: 11:16 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/26/25

Source Type: Deep End

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/24/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	5:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	6/23/25	11:16 AM	MM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/23/25	11:16 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	11:16 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



**Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041
APM 1

Lab# 2062

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Brook Park Swim Club

Sample Collection

Date: 6/23/25

Address: 8190 Rochester Rd
Pittsburgh, PA 15237

Time: 11:16 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/26/25

Source Type: Deep End

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/24/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	5:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	6/23/25	11:16 AM	MM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/23/25	11:16 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	11:16 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor