



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2471

Customer

Facility Name: Schenley
Address: 1 Overlook Dr.
Pittsburgh, PA 15213

Sample Collection

Date: 7/8/25
Time: 10:15 AM
Method: Grab

Sample Final Analysis

Date: 7/11/25
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/9/25 | 9:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/9/25 | 9:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/8/25 | 3:48 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|-----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/8/25 | 10:15 AM | WB | DPD |
| Chlorine: | 10.0 mg/l | 1.0 - 5.0 mg/l | 7/8/25 | 10:15 AM | WB | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/8/25 | 10:15 AM | WB | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2471

Customer

Facility Name: Schenley
Address: 1 Overlook Dr.
Pittsburgh, PA 15213

Sample Collection

Date: 7/8/25
Time: 10:15 AM
Method: Grab

Sample Final Analysis

Date: 7/11/25
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/9/25 | 9:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/9/25 | 9:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/8/25 | 3:48 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|-----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/8/25 | 10:15 AM | WB | DPD |
| Chlorine: | 10.0 mg/l | 1.0 - 5.0 mg/l | 7/8/25 | 10:15 AM | WB | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/8/25 | 10:15 AM | WB | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor