



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 156

Customer

Facility Name: *Holiday Inn - Bridgeville*

Address: *3053 Washington Pike*
Bridgeville, PA 15017

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/18/25*

Time: *12:28 PM*

Method: *Grab*

Sample Final Analysis

Date: *8/21/25*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/25	10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25	10:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/18/25	12:28 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/18/25	12:28 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	12:28 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor