



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 233

Customer

Facility Name: *Mt. Pleasant High School*

Address: *265 State St.*
Mt Pleasant, PA 15666

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *1/19/26*

Time: *9:57 AM*

Method: *Grab*

Sample Final Analysis

Date: *1/22/26*

Time: *11:00 AM*

Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 1/20/26 | 10:30 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 1/20/26 | 10:30 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 1/19/26 | 3:56 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 1/19/26 | 9:57 AM | JC | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 1/19/26 | 9:57 AM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 1/19/26 | 9:57 AM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor