

## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041 APM 3

Lab# 2525

American Pools Management Customer

3261 Babcock Blvd.

Pittsburgh, PA 15237

Torrent of Upper St. Clair Facility Name:

2565 Boyce Plaza Rd. Address:

Upper St. Clair, PA 15241

Matrix: Recreational Water

Source Type: Pool Sample Collection

Date: 7/14/25 Time: 1:44 PM Method: Grab

Sample Final Analysis

Date: 7/17/25 Time: 8:30 AM Analyst: AS

Accredited Analysis	Results Reporting limit	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/15/25	10:45 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/15/25	10:45 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	1:44 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	1:44 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	1:44 PM	AF	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041 APM 3

Lab# 2525

American Pools Management Customer

3261 Babcock Blvd.

Pittsburgh, PA 15237

Torrent of Upper St. Clair Facility Name:

2565 Boyce Plaza Rd. Address:

Upper St. Clair, PA 15241

Matrix: Recreational Water

Source Type: Pool Sample Collection

Date: 7/14/25 Time: 1:44 PM Method: Grab

Sample Final Analysis

Date: 7/17/25 Time: 8:30 AM Analyst: AS

Accredited Analysis	Results Reporting limit	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/15/25	10:45 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/15/25	10:45 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	1:44 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	1:44 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	1:44 PM	AF	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor