



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 177**

**Customer**

Facility Name: Hyatt Place  
Address: 2112 Racetrack  
Washington, PA 15301

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 9/2/25  
Time: 10:40 AM  
Method: Grab

**Sample Final Analysis**

Date: 9/5/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/25	10:00 AM	JC	SM 9222G
Total coliforms:	1/100mls	2/100mls	9/3/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	9/2/25	10:40 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/2/25	10:40 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/25	10:40 AM	GR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor