



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM 3

Lab# 2317

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Laurel Village*

Address: *1000 Penn Center Blvd.*
Pittsburgh, PA 15235

Sample Collection

Date: 8/25/25
Time: 12:00 AM
Method: Grab

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Final Analysis

Date: 8/28/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/25	9:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25	9:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25	3:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	8/25/25	9:16 AM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/25/25	9:16 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25	9:16 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor