



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 313

Customer

Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 6/3/25

Time: 10:15 AM

Method: Grab

Sample Final Analysis

Date: 6/6/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	6/4/25 11:30 AM	AH	SM 9222G
-------------------	--------	--------	-----------------	----	----------

Total coliforms:	0/100mls	2/100mls	6/4/25 11:30 AM	AH	SM 9222B
------------------	----------	----------	-----------------	----	----------

Standard plate count:	0/ml	200/ml	6/3/25 5:45 PM	SL	SM 9215B
-----------------------	------	--------	----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	6/4/25 12:00 PM	AH	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.5 SU	7.2 - 7.8 SU	6/3/25 10:15 AM	JR	DPD
-----	--------	--------------	-----------------	----	-----

Chlorine:	2.5 mg/l	1.0 - 5.0 mg/l	6/3/25 10:15 AM	JR	DPD
-----------	----------	----------------	-----------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/3/25 10:15 AM	JR	Visual
------------	-------	-----------	-----------------	----	--------

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 313

Customer

Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 6/3/25

Time: 10:15 AM

Method: Grab

Sample Final Analysis

Date: 6/6/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	6/4/25 11:30 AM	AH	SM 9222G
-------------------	--------	--------	-----------------	----	----------

Total coliforms:	0/100mls	2/100mls	6/4/25 11:30 AM	AH	SM 9222B
------------------	----------	----------	-----------------	----	----------

Standard plate count:	0/ml	200/ml	6/3/25 5:45 PM	SL	SM 9215B
-----------------------	------	--------	----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	6/4/25 12:00 PM	AH	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.5 SU	7.2 - 7.8 SU	6/3/25 10:15 AM	JR	DPD
-----	--------	--------------	-----------------	----	-----

Chlorine:	2.5 mg/l	1.0 - 5.0 mg/l	6/3/25 10:15 AM	JR	DPD
-----------	----------	----------------	-----------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/3/25 10:15 AM	JR	Visual
------------	-------	-----------	-----------------	----	--------

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor