



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

S-16

Lab# 076

**Customer**

Facility Name: *Courtyard by Marriott*

Address: *1800 Tanger Blvd.  
Washington, PA 15301*

Matrix: *Recreational Water*

Source Type: *Spa*

**Sample Collection**

Date: *6/24/25*

Time: *12:12 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *6/27/25*

Time: *9:20 AM*

Analyst: *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	6/25/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:30 AM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	6/24/25	3:59 PM	AH	SM 9215B
<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Fecal Streptococcus	0/100mls	2/100mls	6/25/25	12:10 PM	EB	SM 9230C

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	8.0 SU	7.2 - 7.8 SU	6/24/25	12:12 PM	GR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:12 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:12 PM	GR	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

S-16

Lab# 076

**Customer**

Facility Name: *Courtyard by Marriott*

Address: *1800 Tanger Blvd.  
Washington, PA 15301*

Matrix: *Recreational Water*

Source Type: *Spa*

**Sample Collection**

Date: *6/24/25*

Time: *12:12 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *6/27/25*

Time: *9:20 AM*

Analyst: *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	6/25/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:30 AM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	6/24/25	3:59 PM	AH	SM 9215B
<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Fecal Streptococcus	0/100mls	2/100mls	6/25/25	12:10 PM	EB	SM 9230C

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	8.0 SU	7.2 - 7.8 SU	6/24/25	12:12 PM	GR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:12 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:12 PM	GR	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor