



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 313

Customer

Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/1/25

Time: 11:45 AM

Method: Grab

Sample Final Analysis

Date: 7/4/25

Time: 9:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | | |
|-------------------|--------|--------|--------|----------|----|----------|
| Escherichia Coli: | Absent | Absent | 7/2/25 | 10:40 AM | EB | SM 9222G |
|-------------------|--------|--------|--------|----------|----|----------|

| | | | | | | |
|------------------|----------|----------|--------|----------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 7/2/25 | 10:40 AM | EB | SM 9222B |
|------------------|----------|----------|--------|----------|----|----------|

| | | | | | | |
|-----------------------|------|--------|--------|---------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 7/1/25 | 5:37 PM | SL | SM 9215B |
|-----------------------|------|--------|--------|---------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | | |
|---------------------|----------|----------|--------|----------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/2/25 | 11:40 AM | AH | SM 9230C |
|---------------------|----------|----------|--------|----------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | | |
|-----|--------|--------------|--------|----------|----|-----|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/1/25 | 11:45 AM | JR | DPD |
|-----|--------|--------------|--------|----------|----|-----|

| | | | | | | |
|-----------|----------|----------------|--------|----------|----|-----|
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/1/25 | 11:45 AM | JR | DPD |
|-----------|----------|----------------|--------|----------|----|-----|

| | | | | | | |
|------------|-------|-----------|--------|----------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/1/25 | 11:45 AM | JR | Visual |
|------------|-------|-----------|--------|----------|----|--------|

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 313

Customer

Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/1/25

Time: 11:45 AM

Method: Grab

Sample Final Analysis

Date: 7/4/25

Time: 9:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | | |
|-------------------|--------|--------|--------|----------|----|----------|
| Escherichia Coli: | Absent | Absent | 7/2/25 | 10:40 AM | EB | SM 9222G |
|-------------------|--------|--------|--------|----------|----|----------|

| | | | | | | |
|------------------|----------|----------|--------|----------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 7/2/25 | 10:40 AM | EB | SM 9222B |
|------------------|----------|----------|--------|----------|----|----------|

| | | | | | | |
|-----------------------|------|--------|--------|---------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 7/1/25 | 5:37 PM | SL | SM 9215B |
|-----------------------|------|--------|--------|---------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | | |
|---------------------|----------|----------|--------|----------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/2/25 | 11:40 AM | AH | SM 9230C |
|---------------------|----------|----------|--------|----------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | | |
|-----|--------|--------------|--------|----------|----|-----|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/1/25 | 11:45 AM | JR | DPD |
|-----|--------|--------------|--------|----------|----|-----|

| | | | | | | |
|-----------|----------|----------------|--------|----------|----|-----|
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/1/25 | 11:45 AM | JR | DPD |
|-----------|----------|----------------|--------|----------|----|-----|

| | | | | | | |
|------------|-------|-----------|--------|----------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/1/25 | 11:45 AM | JR | Visual |
|------------|-------|-----------|--------|----------|----|--------|

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor