

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

C-10

Lab ID No. 02-04041

Lab# 303

Customer

Facility Name: University of Pittsburgh

Address: 3501 Allequippa St.

Pittsburgh, PA 15260

Matrix: Recreational Water

Source Type: Lg Pool Middle 1 Sample Collection

Date: 7/28/25

Time: 11:45 AM Method: Grab

Sample Final Analysis

Date: 7/31/25 Time: 9:00 AM Analyst: AS

Accredited Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent Absent 7/29/25 9:10 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 7/29/25 9:10 AM ΕB SM 9222B Standard plate count: 0/ml 200/ml 7/28/25 2:46 PM EΒ SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/28/25 | 11:45 AM | LM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/28/25 | 11:45 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/28/25 | 11:45 AM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

C-10

Lab ID No. 02-04041

Lab# 303

Customer

Facility Name: University of Pittsburgh

Address: 3501 Allequippa St.

Pittsburgh, PA 15260

Matrix: Recreational Water

Source Type: Lg Pool Middle 1 Sample Collection

Date: 7/28/25

Time: 11:45 AM Method: Grab

Sample Final Analysis

Date: 7/31/25 Time: 9:00 AM Analyst: AS

Accredited Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent Absent 7/29/25 9:10 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 7/29/25 9:10 AM ΕB SM 9222B Standard plate count: 0/ml 200/ml 7/28/25 2:46 PM EΒ SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/28/25 | 11:45 AM | LM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/28/25 | 11:45 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/28/25 | 11:45 AM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith