Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-15

Lab#   166

Customer			**Sample Collection**	
Facility Name:	*Holiday Inn Express - Southpointe*		*Date:*	*6/10/25*
			Time:	11:59 AM
Address:	*4000 Horizon Vue Drive*		*Method:*	*Grab*
	Canonsburg, PA 15317			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*6/13/25*
			Time:	*9:30 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25	11:59 AM	AF	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/10/25	11:59 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	11:59 AM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-15

Lab# 166

Customer

Facility Name:	*Holiday Inn Express - Southpointe*		
Address:	*4000 Horizon Vue Drive*		
	Canonsburg, PA 15317		
Matrix:	*Recreational Water*		
Source Type:	*Pool*		

Sample Collection

Date:	*6/10/25*
Time:	11:59 AM
Method:	*Grab*

Sample Final Analysis

Date:	*6/13/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25	11:59 AM	AF	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/10/25	11:59 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	11:59 AM	AF	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor