



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 063

Customer

Facility Name: Comfort Inn - Meadowlands

Address: 237 Meadowlands Boulevard
Washington, PA 15301

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/28/25

Time: 2:03 PM

Method: Grab

Sample Final Analysis

Date: 5/31/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	2:03 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/28/25	2:03 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	2:03 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 063

Customer

Facility Name: Comfort Inn - Meadowlands

Address: 237 Meadowlands Boulevard
Washington, PA 15301

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/28/25

Time: 2:03 PM

Method: Grab

Sample Final Analysis

Date: 5/31/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	2:03 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/28/25	2:03 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	2:03 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor