

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2630

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Nineteen North Apts

Address: 1050 Nineteen North Dr. Time: Method

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/15/25 Time: 1:49 PM

Method: Grab

Sample Final Analysis

Date: 7/18/25 Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Incubation Date/Time Analy		Method SM 9222G	
Escherichia Coli:	Absent	Absent	7/16/25	11:20 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/16/25	11:20 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	7/15/25	5:35 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25	1:49 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/15/25	1:49 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	1:49 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2630

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Nineteen North Apts

Address: 1050 Nineteen North Dr. Time: Method

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/15/25 Time: 1:49 PM

Method: Grab

Sample Final Analysis

Date: 7/18/25 Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Incubation Date/Time Analy		Method SM 9222G	
Escherichia Coli:	Absent	Absent	7/16/25	11:20 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/16/25	11:20 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	7/15/25	5:35 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25	1:49 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/15/25	1:49 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	1:49 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor