



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 323

Customer

Facility Name: Valley High School
Address: 703 Stevenson Blvd.
New Kensington, PA 15068

Sample Collection

Date: 12/23/25
Time: 1:52 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 12/26/25
Time: 12:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/24/25	11:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/24/25	11:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/23/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	12/23/25	1:52 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/23/25	1:52 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/23/25	1:52 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor