



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**LCP**

**Lab# 2036**

**Customer**

**Facility Name:** Bellvue Park  
**Address:** Lambeth Dr.  
Cranberry, PA 16066

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 9/2/25  
**Time:** 11:35 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 9/5/25  
**Time:** 10:00 AM  
**Analyst:** AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/25	12:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/25	12:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/25	5:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/2/25	11:35 AM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	9/2/25	11:35 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/0/00	11:35 AM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor