



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**N-2**

**Lab# 452**

**Customer**

**Facility Name:** Doubletree Cranberry

**Address:** 910 Sheraton Dr  
Mars, PA 16046

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 2/18/26

**Time:** 11:15 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 2/19/26

**Time:** 4:00 PM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/18/26	3:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/18/26	3:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/18/26	3:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	2/18/26	11:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/18/26	11:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/18/26	11:15 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor