



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-3**

**Lab# 215**

**Customer**

Facility Name: Longwood at Oakmont

Address: 500 Rt. 909  
Verona, PA 15147

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/10/25

Time: 10:35 AM

Method: Grab

**Sample Final Analysis**

Date: 12/12/25

Time: 4:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/10/25	4:10 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/10/25	4:10 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	12/10/25	4:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	12/10/25	10:35 AM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/10/25	10:35 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/10/25	10:35 AM	BH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)