



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2671

Customer

Facility Name: Summer Seat
Address: 114 Gateway Dr.
Pittsburgh, PA 15237

Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 6/3/25
Time: 11:34 AM
Method: Grab

Sample Final Analysis

Date: 6/6/25
Time: 9:30 AM
Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	6/4/25 11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25 11:30 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	6/3/25 5:45 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	6/4/25 12:00 PM	EB	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	6/3/25 11:34 AM	MM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/3/25 11:34 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25 11:34 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2671

Customer

Facility Name: Summer Seat
Address: 114 Gateway Dr.
Pittsburgh, PA 15237

Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 6/3/25
Time: 11:34 AM
Method: Grab

Sample Final Analysis

Date: 6/6/25
Time: 9:30 AM
Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	6/4/25 11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25 11:30 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	6/3/25 5:45 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	6/4/25 12:00 PM	EB	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	6/3/25 11:34 AM	MM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/3/25 11:34 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25 11:34 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor