



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-2**

**Lab# 115**

**Customer**

Facility Name: Hampton Inn  
Address: 2622 Wexford-Bayne Rd.  
Wexford, PA 15090

**Sample Collection**

Date: 12/30/25  
Time: 10:45 AM  
Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 1/2/26  
Time: 10:30 AM  
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/31/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/31/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/25	4:54 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/30/25	10:45 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/30/25	10:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/30/25	10:45 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor