



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2479

Customer

Facility Name: Seven Springs Resort

Address: 777 Waterwheel Dr.
Champion, PA 15622

Matrix: Recreational Water

Source Type: Barvarian Beach Pool

Sample Collection

Date: 6/30/25

Time: 11:28 AM

Method: Grab

Sample Final Analysis

Date: 7/3/25

Time: 9:30 AM

Analyst: 1/0/00

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/1/25 | 10:00 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/1/25 | 10:00 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/30/25 | 4:10 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 6/30/25 | 11:28 AM | JC | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 6/30/25 | 11:28 AM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/30/25 | 11:28 AM | JC | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2479

Customer

Facility Name: Seven Springs Resort

Address: 777 Waterwheel Dr.
Champion, PA 15622

Matrix: Recreational Water

Source Type: Barvarian Beach Pool

Sample Collection

Date: 6/30/25

Time: 11:28 AM

Method: Grab

Sample Final Analysis

Date: 7/3/25

Time: 9:30 AM

Analyst: 1/0/00

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/1/25 | 10:00 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/1/25 | 10:00 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/30/25 | 4:10 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 6/30/25 | 11:28 AM | JC | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 6/30/25 | 11:28 AM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/30/25 | 11:28 AM | JC | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor