



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 105

Customer

Facility Name: *Fairfield Inn*

Address: *107 Bair Blvd.*
New Stanton, PA 15672

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *12/3/25*
Time: *9:31 AM*
Method: *Grab*

Sample Final Analysis

Date: *12/5/25*
Time: *6:00 PM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 12/3/25 | 5:30 PM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/3/25 | 5:30 PM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/3/25 | 5:30 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 12/3/25 | 9:31 AM | JC | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 12/3/25 | 9:31 AM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/3/25 | 9:31 AM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor