



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

S-12

Lab# 017

**Customer**

Facility Name: Baldwin H.S.

Address: 4653 Clairton Boulevard  
Pittsburgh, PA 15236

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 8/25/25

Time: 9:55 AM

Method: Grab

**Sample Final Analysis**

Date: 8/28/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/25	8:20 AM	AS SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25	8:20 AM	AS SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25	3:50 PM	AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/25/25	9:55 AM	BL DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/25/25	9:55 AM	BL DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25	9:55 AM	BL Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor