

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

N-10

Lab ID No. 02-04041

Lab# 2207

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Fox Chapel Yacht Club Date: 8/19/25
Time: 10:50 AM

Address: 1366 Old Freeport Road Method: Grab

Pittsburgh, PA 15238

Matrix: Recreational Water Sample Final Analysis

Date: 8/22/25

Source Type: Shallow End Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	10:05 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	10:05 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/25	4:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/19/25	10:50 AM	ВН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/19/25	10:50 AM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/25	10:50 AM	вн	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith