



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 046**

**Customer**

**Facility Name:** Carrick High School  
**Address:** 125 Parkfield St.  
Pittsburgh, PA 15210

**Matrix:** Recreational Water

**Source Type:** Pool Shallow

**Sample Collection**

**Date:** 10/20/25  
**Time:** 10:29 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 10/23/25  
**Time:** 10:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	10/21/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	10/21/25	10:00 AM	JC	SM 9222B
Standard plate count:	50/ml	C	10/20/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	10/20/25	10:29 AM	MM	DPD
Chlorine:	2.0 mg/l	B	10/20/25	10:29 AM	MM	DPD
Turbidity:	1 NTU	A	10/20/25	10:29 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor