



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-1**

**Lab# 186**

**Customer**

Facility Name: Jewish Community Center

Address: 345 Kane Blvd.  
Pittsburgh, PA 15243

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 1/6/26

Time: 2:30 PM

Method: Grab

**Sample Final Analysis**

Date: 1/9/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/7/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/7/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	1/6/26	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	1/6/26	2:30 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	1/6/26	2:30 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/6/26	2:30 PM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor