



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 416

Customer

Facility Name: Drury Hotel
Address: 101 Ridge Rd.
Pittsburgh, PA 15205

Sample Collection

Date: 5/27/25
Time: 9:15 AM
Method: Grab

Matrix: Recreational Water

Source Type: Spa

Sample Final Analysis

Date: 5/30/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	5/28/25 9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25 9:15 AM	EB	SM 9222B
Standard plate count:	120/ml	200/ml	5/27/25 2:55 PM	AH	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	5/28/25 11:30 AM	AH	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	5/27/25 9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25 9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25 9:15 AM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 416

Customer

Facility Name: Drury Hotel
Address: 101 Ridge Rd.
Pittsburgh, PA 15205

Sample Collection

Date: 5/27/25
Time: 9:15 AM
Method: Grab

Matrix: Recreational Water
Source Type: Spa

Sample Final Analysis

Date: 5/30/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	120/ml	200/ml	5/27/25	2:55 PM	AH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/28/25	11:30 AM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	9:15 AM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor