

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2274

CustomerSample CollectionFacility Name:Hosanna CampDate: 6/23/25Time:11:57 A

Address: 400 Sherwood Rd Time: 11:57 AM Method: Grab

Pittsburgh, PA 15221

Matrix: Recreational Water Sample Final Analysis

Date: 6/26/25

Source Type: Shallow End Time: 9:00 AM
Analyst: AS

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent 6/24/25 9:15 AM SM 9222G Absent EΒ Total coliforms: 0/100mls 2/100mls 6/24/25 9:15 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 6/23/25 3:03 PM AΗ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	6/23/25	11:57 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/23/25	11:57 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	11:57 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2274

CustomerSample CollectionFacility Name:Hosanna CampDate: 6/23/25Time:11:57 A

Address: 400 Sherwood Rd Time: 11:57 AM Method: Grab

Pittsburgh, PA 15221

Matrix: Recreational Water Sample Final Analysis

Date: 6/26/25

Source Type: Shallow End Time: 9:00 AM
Analyst: AS

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent 6/24/25 9:15 AM SM 9222G Absent EΒ Total coliforms: 0/100mls 2/100mls 6/24/25 9:15 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 6/23/25 3:03 PM AΗ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	6/23/25	11:57 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/23/25	11:57 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	11:57 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor