



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 482

Customer

Facility Name: YMCA - Schneider
Address: 2001 Ehrman Rd
Cranberry, PA 16066

Sample Collection

Date: 1/5/26
Time: 11:45 AM
Method: Grab

Matrix: Recreational Water

Source Type: Large Pool

Sample Final Analysis

Date: 1/8/26
Time: 10:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 1/6/26 | 10:00 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 1/6/26 | 10:00 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 1/5/26 | 5:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 1/5/26 | 11:45 AM | BH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 1/5/26 | 11:45 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 1/5/26 | 11:45 AM | BH | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)