



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665

Lab ID No. 02-04041

W-2

Lab# 150

Laboratory Analysis Report

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Hilton Garden Inn	Date:	12/8/25			
Address:	303 Park Manor Dr. Pittsburgh, PA 15205	Time:	10:45 AM			
Matrix:	Recreational Water	Method:	Grab			
Source Type:	Pool	<u>Sample Final Analysis</u>				
		Date:	12/11/25			
		Time:	9:30 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	12/9/25	9:10 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/9/25	9:10 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/8/25	5:00 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	12/8/25	10:45 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	12/8/25	10:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/8/25	10:45 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor