

## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

W-10

Lab ID No. 02-04041

Lab# 2478

Customer

Facility Name:

Seven Oaks C.C.

Address:

132 Lisbon Road

Beaver, PA 15009

Matrix:

Recreational Water

Source Type:

Wading Pool

Sample Collection

Date:

4:14 PM

Time:

Method: Grab

Sample Final Analysis

Date:

7/10/25 9:30 AM

Time: Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	11:15 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	11:15 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/7/25	4:14 PM	АН	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/7/25	4:14 PM	АН	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	4:14 PM	АН	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

W-10

Lab ID No. 02-04041

Lab# 2478

Customer

Facility Name:

Seven Oaks C.C.

Address:

132 Lisbon Road

Beaver, PA 15009

Matrix:

Recreational Water

Source Type:

Wading Pool

Sample Collection

Date:

4:14 PM

Time:

Method: Grab

Sample Final Analysis

Date:

7/10/25 9:30 AM

Time: Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	11:15 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	11:15 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/7/25	4:14 PM	АН	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/7/25	4:14 PM	АН	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	4:14 PM	АН	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor