

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-14

Lab ID No. 02-04041

Lab# 322

Sample Collection Customer

Facility Name: Upper St. Clair Rec. 8/11/25 Date: 3:28 PM Time: Method: Grab

Address: 1551 Mayview Rd. Pittsburgh, PA 15241

Sample Final Analysis Matrix: Recreational Water Date: 8/14/25

Time: 9:00 AM Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:30 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:30 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/12/25	11:25 AM	EB	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	3:28 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/11/25	3:28 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	3:28 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-14

Lab ID No. 02-04041

Lab# 322

Sample Collection Customer

Facility Name: Upper St. Clair Rec. 8/11/25 Date: 3:28 PM Time: Method: Grab

Address: 1551 Mayview Rd. Pittsburgh, PA 15241

Sample Final Analysis Matrix: Recreational Water Date: 8/14/25

Time: 9:00 AM Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:30 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:30 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/12/25	11:25 AM	EB	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	3:28 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/11/25	3:28 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	3:28 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor