



**Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2113

Customer

*American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237*

Facility Name: Clinton Lake

Sample Collection

Date: 8/12/25

Time: 1:18 PM

Address: 124 Clinton Dr.
Clinton, PA 15026

Sample Final Analysis

Sample Final Analysis

Date: 8/15/25
Time: 8:00 AM

Matrix: Recreational Water

Time: 9:00 AM
Analyst: AS

Source Type: *Pool*

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:58 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	1:18 PM	AH DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/12/25	1:18 PM	AH DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	1:18 PM	AH Visual

Sample comments

Anabee Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith | Lead Supervisor



**Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2113

Customer

*American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237*

Facility Name: Clinton Lake

Sample Collection

Date: 8/12/25

Time: 1:18 PM

Address: 124 Clinton Dr.
Clinton, PA 15026

Sample Final Analysis

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM

Matrix: Recreational Water

Time: 9:00 AM
Analyst: AS

Analyst: AS

Source Type:

Date/Time **Analyst**

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:58 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	1:18 PM	AH DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/12/25	1:18 PM	AH DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	1:18 PM	AH Visual

Sample comments

Anabee Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith | Lead Supervisor