



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2234**

**Customer**

Facility Name: Green Oaks C.C.  
Address: 5741 3rd Street  
Verona, PA 15147

**Sample Collection**

Date: 7/8/25  
Time: 1:28 PM  
Method: Grab

Matrix: Recreational Water  
Source Type: Shallow End

**Sample Final Analysis**

Date: 7/11/25  
Time: 9:00 AM  
Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/9/25               | 9:00 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/9/25               | 9:00 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/8/25               | 3:48 PM | AH      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 7/8/25    | 1:28 PM | EH      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 7/8/25    | 1:28 PM | EH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/8/25    | 1:28 PM | EH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2234**

**Customer**

**Facility Name:** Green Oaks C.C.  
**Address:** 5741 3rd Street  
Verona, PA 15147

**Sample Collection**

**Date:** 7/8/25  
**Time:** 1:28 PM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Shallow End

**Sample Final Analysis**

**Date:** 7/11/25  
**Time:** 9:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/9/25               | 9:00 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/9/25               | 9:00 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/8/25               | 3:48 PM | AH      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 7/8/25    | 1:28 PM | EH      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 7/8/25    | 1:28 PM | EH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/8/25    | 1:28 PM | EH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor