

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 C-11

Lab# 067

Customer

Facility Name: Cork Factory

Address:

2349 Rail Road St. Pittsburgh, PA 15222

Matrix:

Recreational Water

Source Type:

Spa

0/100mls

Sample Collection

Date: Time: 6/17/25 8:55 AM

Method: 8:55 Method:

Sample Final Analysis

Date:

6/20/25

Time: Analyst:

11:30 AM

9:00 AM AS

EΒ

SM 9230C

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	5:00 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method

6/18/25

Field Analysis	Results	Reporting limit	D	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25	8:55 AM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/17/25	8:55 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	8:55 AM	LM	Visual

2/100mls

Sample comments

Fecal Streptococcus

(When exceeding reporting limit pool or spa is unfit)

andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 C-11

Lab# 067

Customer

Facility Name: Cork Factory

Address:

2349 Rail Road St. Pittsburgh, PA 15222

Matrix:

Recreational Water

Source Type:

Spa

0/100mls

Sample Collection

Date: Time: 6/17/25 8:55 AM

Method: 8:55 Method:

Sample Final Analysis

Date:

6/20/25

Time: Analyst:

11:30 AM

9:00 AM AS

EΒ

SM 9230C

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	5:00 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method

6/18/25

Field Analysis	Results	Reporting limit	D	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25	8:55 AM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/17/25	8:55 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	8:55 AM	LM	Visual

2/100mls

Sample comments

Fecal Streptococcus

(When exceeding reporting limit pool or spa is unfit)

andre Smith, Lead Supervisor