B & R Pools and Swim Shop

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2392

Customer		**_Sample Collection_**
Facility Name:	*Park Swim Club*	*Date:* 6/17/25
		Time: 12:57 PM
Address:	*College Park Dr.*	*Method:* Grab
	Monroeville, PA 15146	
		Sample Final Analysis
Matrix:	*Recreational Water*	*Date:* 6/20/25
		Time: 9:00 AM
Source Type:	*Deep End*	*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/17/25	12:57 PM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/17/25	12:57 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	12:57 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer		_Sample Collection_	
Facility Name:	Park Swim Club	Date:	6/17/25
		Time:	12:57 PM
Address:	College Park Dr.	Method:	Grab
	Monroeville, PA 15146		
		Sample Final Analysis	
Matrix:	Recreational Water	Date:	6/20/25
		Time:	9:00 AM
Source Type:	Deep End	Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/17/25	12:57 PM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/17/25	12:57 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	12:57 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor