

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2523

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Thorn Run Apts

Results

Address: 700 Lee Drive

Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis

Sample Collection

Date: 6/17/25

Time: 11:45 AM

Method: Grab

Sample Final Analysis

Incubation Date/Time

 Date:
 6/20/25

 Time:
 9:00 AM

 Analyst:
 AS

Analyst

Method

Escherichia Coli: Absent Absent 6/18/25 9:00 AM EΒ SM 9222G Total coliforms: 0/100mls EΒ 2/100mls 6/18/25 9:00 AM SM 9222B Standard plate count: 0/mI200/ml 6/17/25 3:03 PM EΒ SM 9215B

Reporting limit

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/17/25	11:45 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/17/25	11:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	11:45 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2523

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Thorn Run Apts

Results

Address: 700 Lee Drive

Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis

Sample Collection

Date: 6/17/25

Time: 11:45 AM

Method: Grab

Sample Final Analysis

Incubation Date/Time

 Date:
 6/20/25

 Time:
 9:00 AM

 Analyst:
 AS

Analyst

Method

Escherichia Coli: Absent Absent 6/18/25 9:00 AM EΒ SM 9222G Total coliforms: 0/100mls EΒ 2/100mls 6/18/25 9:00 AM SM 9222B Standard plate count: 0/mI200/ml 6/17/25 3:03 PM EΒ SM 9215B

Reporting limit

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/17/25	11:45 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/17/25	11:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	11:45 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor