



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

**Lab# 2175**

**Customer**

**Facility Name:** Elmhurst Swim Club  
**Address:** 1 South Wilmont Ave.  
Washington, PA 15301

**Sample Collection**

**Date:** 6/3/25  
**Time:** 10:43 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Baby Pool

**Sample Final Analysis**

**Date:** 6/6/25  
**Time:** 9:30 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/4/25               | 10:20 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/4/25               | 10:20 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/3/25               | 4:45 PM  | EB      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 6/3/25    | 10:43 AM | GR      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 6/3/25    | 10:43 AM | GR      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/3/25    | 10:43 AM | GR      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

**Lab# 2175**

**Customer**

**Facility Name:** Elmhurst Swim Club  
**Address:** 1 South Wilmont Ave.  
Washington, PA 15301

**Sample Collection**

**Date:** 6/3/25  
**Time:** 10:43 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Baby Pool

**Sample Final Analysis**

**Date:** 6/6/25  
**Time:** 9:30 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/4/25               | 10:20 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/4/25               | 10:20 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/3/25               | 4:45 PM  | EB      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 6/3/25    | 10:43 AM | GR      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 6/3/25    | 10:43 AM | GR      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/3/25    | 10:43 AM | GR      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor