



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-13**

**Lab# 2435**

**Customer**

Facility Name: *Trellis North Fayette*  
Address: *1500 Park Lane Drive*  
*Pittsburgh, PA 15275*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *6/3/25*  
Time: *10:58 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *6/6/25*  
Time: *9:30 AM*  
Analyst: *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/4/25     | 9:50 AM   | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/4/25     | 9:50 AM   | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/3/25     | 4:25 PM   | EB      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time | Analyst  | Method |        |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 6/3/25    | 10:58 AM | AH     | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 6/3/25    | 10:58 AM | AH     | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/3/25    | 10:58 AM | AH     | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-13**

**Lab# 2435**

**Customer**

Facility Name: Trellis North Fayette  
Address: 1500 Park Lane Drive  
Pittsburgh, PA 15275

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 6/3/25  
Time: 10:58 AM  
Method: Grab

**Sample Final Analysis**

Date: 6/6/25  
Time: 9:30 AM  
Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/4/25     | 9:50 AM   | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/4/25     | 9:50 AM   | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/3/25     | 4:25 PM   | EB      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time | Analyst  | Method |        |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 6/3/25    | 10:58 AM | AH     | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 6/3/25    | 10:58 AM | AH     | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/3/25    | 10:58 AM | AH     | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor