



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2449

Customer

Facility Name: *Rodgers-McFeely*

Address: *910 Jefferson Street*
Latrobe, PA 15650

Sample Collection

Date: *5/27/25*
Time: *2:13 PM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *5/30/25*
Time: *9:00 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 9:45 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 9:45 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 5/27/25 | 2:13 PM | JC | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 2:13 PM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 2:13 PM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anaë Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2449

Customer

Facility Name: Rodgers-McFeely
Address: 910 Jefferson Street
Latrobe, PA 15650

Sample Collection

Date: 5/27/25
Time: 2:13 PM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Pool

Date: 5/30/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 9:45 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 9:45 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 5/27/25 | 2:13 PM | JC | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 2:13 PM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 2:13 PM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anaë Smith