



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-12**

**Lab# 2304**

**Customer**

**Facility Name:** *Kennywood Park*

**Address:** *4800 Kennywood Blvd.  
West Mifflin, PA 15122*

**Matrix:** *Recreational Water*

**Source Type:** *PGH Plunge*

**Sample Collection**

**Date:** *7/14/25*

**Time:** *10:14 AM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *7/17/25*

**Time:** *8:30 AM*

**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Present	Absent	7/15/25	10:15 AM	EB	SM 9222G
Total coliforms:	4/100mls	2/100mls	7/15/25	10:15 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	10:14 AM	SL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/14/25	10:14 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	10:14 AM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-12**

**Lab# 2304**

**Customer**

**Facility Name:** *Kennywood Park*

**Address:** *4800 Kennywood Blvd.*  
*West Mifflin, PA 15122*

**Matrix:** *Recreational Water*

**Source Type:** *PGH Plunge*

**Sample Collection**

**Date:** *7/14/25*

**Time:** *10:14 AM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *7/17/25*

**Time:** *8:30 AM*

**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Present	Absent	7/15/25	10:15 AM	EB	SM 9222G
Total coliforms:	4/100mls	2/100mls	7/15/25	10:15 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	10:14 AM	SL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/14/25	10:14 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	10:14 AM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor